

City of Lynchburg, Procurement Division
900 Church Street, Lynchburg, VA 24504
Telephone No: 434-455-3961
Fax No: 434-845-0711

Date: 2/4/05

From: V. Eloise Bowling, CPPB, Senior Buyer

RE: Addendum #02 – Proposed Roofing Project - 05-0459-BG

Bids will only be accepted from those vendors in attendance at the mandatory pre-bid meeting.

The attached addendum is a result from the pre-bid meeting held January 25, 2005, and additional questions received.

V. Eloise Bowling

V. Eloise Bowling, CPPB
Senior Buyer

Please sign and return as part of the original bid package.

READ TERMS AND CONDITIONS AND SIGN

In compliance with the above Invitation for Bid, and subject to all the conditions hereof, the undersigned offers and agrees to comply with any or all of the terms and conditions contained herein, or as mutually agreed upon by subsequent negotiations. This form shall become part of the final file.

Company Name:
Authorized Signature:
Print Name:

Address:
Title:
Telephone #:

Date:
Fax #:

Addendum No 2

In reference to the pre-bid meeting held on Tuesday, January 25, 2005, and additional questions received, please make the following additions/corrections to the specifications.

Bid Opening Date changed to 3:00 p.m. Wednesday, February 16, 2005

QUESTION:

1. Section III - Supplemental Special Conditions 7.2.A

Please verify membrane wanted -

ANSWER:

As stated in the specification, the membrane shall be thermoplastic. The Firestone 60 mil ultra ply is listed as an approved manufacture. The use of solvent based adhesive would be acceptable using the non fleece back membrane; however, odor protection will be required by the contractor. The contractor shall include installing a temporary charcoal filter on air intakes to HVAC in his pricing. This would minimize complaints on odors from the solvent based adhesives.

QUESTION:

2. Club House - Please advise type of deck (metal or concrete) - Is there a structural slope in decking? If so can we just install crickets?

ANSWER

Reference Section 7.1.1 - the deck for the club house is metal. There is no structural slope in the decking.

QUESTION:

3. Carter Glass - Do we use hot asphalt or cold applied adhesive to install insulation and modified bitumen

ANSWER:

Reference Section 7.1.2 of the specifications, cold process adhesives shall be used to install insulation and cap sheet.